



GRAFTON
Massachusetts

RECEIVED TOWN CLERK
GRAFTON, MA

Katrina Koshivos <koshivosk@graffon-ma.gov>

ZBA Case #883

2022 MAR 17 | AM 11:41

1 message

Nancy Connors <connorsn@graffon-ma.gov>
To: Zoning Department <zba@graffon-ma.gov>

Wed, Mar 16, 2022 at 3:00 PM

The applicant needs to be 10 feet to the septic tank and 20 feet to the leach field, and 10 feet to the well. Thank you

Nancy Connors

Office Manager

Town of Grafton

Health Department

30 Providence Road

Grafton, MA 01519

Phone: 508-839-5335 X 1119

Fax: 508-839-8559

connorsn@graffon-ma.gov

www.graffon-ma.gov

Follow Us: [Facebook](#) | [Twitter](#)

When responding, please remember the Secretary of State considers e-mail a public record.

Consider the environment before printing this e-mail.

PLEASE BE ADVISED, THE NEW HOURS AT THE MUNICIPAL CENTER EFFECTIVE 7/5/2021 ARE AS FOLLOWS:

MONDAY, WEDNESDAY, & THURSDAY 8:30-4:30

TUESDAY 8:30 - 7:00 P.M.

FRIDAY 8:30 - 1:00 P.M.

RECEIVED

MAR 17 2022

Zoning Board of Appeals